

Accordingly, the maximum flow that can pass through the system and achieve optimal treatment is directly related to the UVT. The table below summarises the flowrate at which the target dose of 24mJ/cm² can be achieved at various UVT values (based on information from the equipment supplier).

UVT (%)	20	25	30	35	40	45	50
Flow (L/s)	50	90	140	200	279	350	450

Supplied is a [spreadsheet with SCADA data](#) for:

- UVT (%)
- UV Receive Flow – Total Clarifier and Oxidation Pond discharge flow (L/s)
- UV reactor status (off)

Please note that the enclosed link will expire on 7 June 2025, 10:53 AM.

To aid with interpretation of the data analysis has been undertaken to illustrate if adequate UV disinfection was achieved at each point in time, using the SCADA data and the table above – results are supplied in the spreadsheet:

- Optimal Disinfection Treatment (True or False)

Note:

1. Interpolation was used for values withing the numbers shown in the table.
2. Assumed 10% UVT is the minimum value at which adequate UV treatment can be provided for flows up to 20L/s.

Discharge Flow - Data Assessment for UV disinfection:

The UV reactor status was shown 'off' at only three times (listed below). The data reflects that the UV plant operates continuously.

- 04 January 2023 at 12:40pm (<10 minutes)
- 10 May 2024 at 1:54pm (<10 minutes)
- 25 March 2025 at 10:09am (<10 minutes)

The UV system runs 24 hours per day. The data assessment for disinfection is indicated below:

Date Range	Optimal UV Disinfection Achieved (approximate % of time) *
May 2019 - December 2019	99.7
2020	99.4
2021	98.1
2022	84.6
2023	81.8
2024	89.9
January 2025 - April 2025	94.8

* Maintenance and calibration time spent in the UV system have not been accounted for.

We trust the above information satisfactorily answers your request.

Kind regards,

Democracy Services Team
Corporate Services | Queenstown Lakes District Council
P: +64 3 441 0499
E: information.request@qldc.govt.nz